

BASS SERVICES

PO BOX 21
HERTFORD NC
PHONE (252) 426-1897
FAX (252) 426-3967

August 12, 2026

Jake Forbes/United Country Real Estate
887 Snug Harbor Rd
Hertford, NC 27944

RE: Septic Tank Inspection
887 Snug Harbor Rd
Hertford, NC 27944

Septic Tank Pumped:

Upon visual inspection-

- No Visible Damage
- Concrete Baffle is in Good Working Condition
- Tank Approx. 14 feet from the rear of the house
- No clean out visible between the tank and the house
- Inlet Pipe is Damaged, allowing mud and water into the tank

Distribution Box Cleaned:

Upon visual inspection-

- Good Condition
- Box Appears to be Level
- Four Outfall Drain Lines
- Two Outfall Drain Lines are detached from the D Box about 3 inches

Drain Field:

- Observed No Trees Over Drain Field Area
- Four Lines 100 LF
- Two Drain Lines appear to be detached from the outfall pipes
- Observed No Buildings or Obstructions



NCOWCICB INSPECTOR NO. 69051
JOHNNY L. BASS

