

CLEVELAND COUNTY HEALTH DEPARTMENT  
IMPROVEMENT PERMIT  
315 Grover St., Shelby, NC 28150  
(704) 484-5130


# 105243

Owner / Agent Frank & Molly Savage Property Address 105 Van Dyke Rd Phone No. 373-0898  
State Rd. # 4 TwN# Kings Creek 415 Directions to property 74C, TR Bethlehem Rd,  
S/D MHP Lot# Cross over I-85, cross over Dixon School Rd, TR at Van Dyke. Prop on  
corner of Van Dyke and Bethlehem on L

Watershed Name N/A Watershed Class N/A Critical Area: Y (N) Acreage 3.0

Valid without expiration ( ) Valid for five years ( )  
(plat attached) (site plan attached)  
Authorization to construct issued: Date 3/9/00  
Single Family ( ) Multi-Family ( ) House ( )  
MH ( ) Business ( ) Other \_\_\_\_\_  
Water Supply: Public ( ) Private ( ) Community ( )  
Slab ( ) Crawl Space ( ) Basement with plumbing ( )  
Basement without plumbing ( )

New installation ( ) Repair ( )  
No. of Bedrooms 2 No. of residents 4 design flow 240 gal/day  
LTAR 0.30 gpd/ft<sup>2</sup> Conventional System ( ) Pump to conventional ( )  
Alternative System ( ) system type TTLF 12" Large Diameter Pipe  
Septic Tank 1000 gal. Pump tank \_\_\_\_\_ gal. Grease trap \_\_\_\_\_ gal.  
Nitrification field 800 sq. ft. No. of lines 4 Width 18"  
Length 80' Depth of gravel N/A max. trench bottom depth 18" 5'0"  
depth of cover 6" Repair area system type LPP



Operation Permit

System Classification TTLF Insp. Freq. N/A

Contractor \_\_\_\_\_

Env. Health Specialist \_\_\_\_\_

Date \_\_\_\_\_

This improvement permit shall be valid upon a showing to the Department that the site and soil conditions are unaltered, that the facility, design wastewater flow, and wastewater characteristics are not increased, and that a wastewater system can be installed that meets the permitting requirements in effect on the date the improvement permit was issued. Improvement permits for which a plat is provided shall be valid without expiration. Improvement permits for which a site plan is provided shall be valid for five years. This permit is subject to revocation if the site plan or plat, whichever is applicable, or the intended use changes.

The health department shall issue an authorization to construct prior to the installation or repair of wastewater system when it has determined after a field investigation that the system can be installed and operated in compliance with Article 11 of Chapter 130A of the general statutes of NC and Rules adopted pursuant to this Article. It will be valid for a period equal to the period of validity of the improvement permit, not to exceed five years.

Condition(s) of Issuance Keep 15' off basement cut (side slope), 10' off all property  
and water lines, 5' off proposed drilled well. Install system SHALLOW with  
trench bottoms no deeper than (18" shallow side). Keep all lines on contour

Owner or Agent Frank Savage Date 3/9/00 Environmental Health Specialist Jamie Camp CIST Date 03/09/00