

Other Options

[Return to menu](#)
[Plot this site in State Library Digital Atlas](#)
[Plot this site in Google Maps](#)
 View scanned well log (5/23/2006 12:55:37 PM)

Section 7: Well Test Data

Total Depth: 225
Static Water Level: 85
Water Temperature:

Air Test *

6 gpm with drill stem set at 220 feet for 1 hours.
Time of recovery 30 hours.
Recovery water level 85 feet.
Pumping water level feet.

Time of recovery 30 hours.

Recovery water level 85 feet.

Pumping water level feet.

** During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.*

Section 8: Remarks

Section 9: Well Log

Geologic Source

Unassigned

[illegible]

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name: CHARLES BERGET
Company: UNIVERSAL DRILLING
License No: WWC-519
Date Completed: 1/5/2005

From	To	Diameter
0	225	6

Casing

From	To	Diameter	Wall Thickness	Pressure Rating	Joint	Type
-2	225	6	0.250		WELDED	STEEL

Completion (Perf/Screen)

From	To	Diameter	# of Openings	Size of Openings	Description
225	225	6			OPEN BOTTOM

Annular Space (Seal/Grout/Packer)

From	To	Description	Cont. Fed?
0	0	BENTONITE	Y