



IMPROVEMENT PERMIT

Stanly County Commons
1000 N. First St.
Suite 13-A
Albemarle, NC 28001
Phone: (704) 986-3675

For Office Use Only

*CDP File Number 401004 - 1
County ID Number: 3535
Evaluated For: NEW

PERMIT VALID UNTIL: 04/09/2029

***NOTE TO INSPECTIONS DIVISION:** Building Permits cannot be issued with this Improvement Permit.

Applicant: JERRY CRAYTON
Address: 12327 MISSION CH RD
City: LOCUST
State/Zip: NC 28097
Phone #: _____

Property Owner: JERRY CRAYTON
Address: 12327 MISSION CH RD
City: LOCUST
State/Zip: NC. 28097
Phone #: _____

Property Location & Site Information

Address: FLINT RIDGE RD ALBEMARLE, NC 28001
Subdivision: _____ Block/Phase: NEW Lot: 4
Directions
Road #: _____ LOT 4
Structure: SINGLE FAMILY
of Bedrooms: 4
of People: 8
*Water Supply: NEW WELL

System Specifications

Initial System

Usable Soil Depth: 28

Design Flow: 480

Soil Application Rate: 0.2500

*System Classification/Description:

TYPE III G. OTHER NON-CONV. TRENCH SYSTEMS

*Proposed System:

25% REDUCTION

Minimum Trench Depth: _____ Inches

Maximum Trench Depth: 16 Inches

Septic Tank: 1000 Gallons

Pump Required ☐ Yes ☐ No ☒ May Be Required

Pump Tank: _____ Gallons

Repair System Required: ☒ Yes ☐ No ☐ No, but has Available Space

Repair System

Usable Soil Depth: 28

Soil Application Rate: 0.250

*System Classification/Description:

TYPE III G. OTHER NON-CONV. TRENCH SYSTEMS

*Proposed System: 25% REDUCTION

Minimum Trench Depth: _____ Inches

Maximum Trench: Depth: _____ Inches

Pump Required: ☐ Yes ☐ No ☐ May Be Required

Pump Tank: _____ Gallons

No grading or construction activity is allowed in areas designated for system and repair without approval of Health Department.


*Site Modifications

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

*Permit Conditions

Initial and repair systems are 25% Reduction. 16" trench depth will require additional cover.

Jerry Crayton
Flint Ridge Rd. Lot 4
CDP401004 TR3535



1 inch = 60 feet