



Owner: Krista Kroll Location: 269 Chico Cemetery Rd, Pray Permit Number: 20-086

Permit Status:

☒ Approved ☐ Denied _____

☐ Need more information _____

Wastewater design flow 400 gpd Bedrooms 5 Tank(s) Required (1) 1500 gallon with filter

Drainfield components 3 laterals 64ft long, 2ft wide, max 3ft deep,

of gravelless chambers, connected to a leveled, water-tested, d'box,

AND installed according to the APPROVED Park County layout and design

Call 48hrs in advance for inspection before backfilling.

Approved by  Permit valid until: 7/29/2022



ONSITE WASTEWATER PERMIT

This is a permit to install a septic system. The Park County Sanitarian must be contacted 24 hours in advance to schedule an inspection before the system can be backfilled. After the system is approved, this becomes the permit to operate the septic system. **No changes can be made to the approved plans and specifications without approval from the Park County Sanitarian.**