

Other Options

[Return to menu](#)
[Plot this site in State Library Digital Atlas](#)
[Plot this site in Google Maps](#)

Section 7: Well Test Data

Total Depth: 301
Static Water Level: 234
Water Temperature:

Section 1: Well Owner(s)

1) KROLL, KRISTA (MAIL)
15317 N CURRY AVE
LODI CA 95240 [07/17/2018]
2) KROLL, KRISTA (WELL)
TBD CHICO CEMETARY RD
PRAY MT 59065 [07/17/2018]

Section 2: Location

Township	Range	Section	Quarter Sections			
06S	08E	11	SE¼	NW¼	SW¼	SW¼
County			Geocode			
PARK						
Latitude		Longitude		Geomethod		Datum
45.324389		-110.716667		NAV-GPS		NAD27
Ground Surface Altitude		Ground Surface Method			Datum	Da

Air Test *

30 gpm with drill stem set at 295 feet for 1 hours.
Time of recovery 1 hours.
Recovery water level 234 feet.
Pumping water level _ feet.

** During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.*

Addition

BUCKEYE PLACER MINOR 483

Block	Lot
	D-1-A

Section 3: Proposed Use of Water

DOMESTIC (1)

Section 4: Type of Work

Drilling Method: ROTARY
Status: NEW WELL

Section 5: Well Completion Date

Date well completed: Tuesday, July 17, 2018

Section 6: Well Construction Details

Borehole dimensions

From	To	Diameter
0	301	7.6

Casing

From	To	Diameter	Wall Thickness	Pressure Rating	Joint	Type
-2	300	6.6	0.25		WELDED	A53B STEEL

Completion (Perf/Screen)

From	To	Diameter	# of Openings	Size of Openings	Description
300	301	7.6			OPEN BOTTOM

Annular Space (Seal/Grout/Packer)

From	To	Description	Cont. Fed?
0	25	BENTONITE	Y

Section 9: Well Log

Geologic Source

112DRFT - GLACIAL DRIFT

[illegible]

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name: WILL HAYES

Company: HAYES DRILLING

License No: WWC-361

Date Completed: 7/17/2018