

Deaf Smith County Culvert Specifications Policy

All culverts installed on county right-of-ways must meet the following minimum standards.

- All Culverts must be at least 24 inches in diameter
- Slick Steel Culverts must be at least $\frac{1}{4}$ inch wall thickness
- Corrugated Metal Culverts must be at least 16 gage size
- Pre-cast Concrete Culverts must be at least 4000 psi

The application of the above specifications will be determined by the County Commissioner and Precinct Foreman.

Deaf Smith County Judge

D.J. Wagner

Adopted by Deaf Smith County Commissioners Court this March 28th, 2016