



CORPORATE OFFICE

**7211 Hiawatha Pkwy
Spring Hill, FL 34606
(352)799-1500**

**WWW.ADPASSOC.COM
WWW.TEXASFHAINSPCTIONS.COM**

July 26, 2021

Kenny Smith, Ron Freeman
Clayton Homes - Killeen
3800 E Central Texas Parkway
Killeen, TX 76543

Re: FHA Foundation Certification – Hadley, Steven & Crystal 762 CR 131 Gatesville, TX 76528

I have reviewed the foundation plan and installation data for the SE Homes TX, Model: MA34764AH21, Address: 762 CR 131 Gatesville, TX 76528, and find that the pier spacing and longitudinal tie down locations and spacing, along with other requirements, are in conformance with State of Texas Manufactured Home Installation Standards latest edition and HUD requirements for manufactured home installations.

The home is to be installed in a non-flood plain designated area, a minimum of 1500 PSF soil bearing and in accordance with the State of Texas installation standards. The following on site requirements are required in addition to the manufacturer's installation instructions and State of Texas installation standards:

1. Structural skirting shall be installed after the foundation is fully in place.
2. Non-structural members such as axles, wheels, hitches and tongues shall be removed from the structure.

Upon completion of the above, the foundation of the subject structure will meet the intent of the US Department of Housing and Urban Development "Permanent Foundations Guide for Manufactured Housing, "Handbook HUD-007487, September 1996 edition and HUD Handbook 7584" and State of Texas, Chapter 80, Manufactured Housing Rules.

Certified to this date: July 26, 2021