



Martin-Tyrrell-Washington

DISTRICT HEALTH



Public Health
Prevent. Promote. Protect.

Wes Gray, MPA, MPH, Health Director

252.793.3023 (p) • 252.791.3108 (f) • mtwdistricthealth.org

PIN _____

MARTIN COUNTY HEALTH DEPARTMENT

Permit Number _____

IMPROVEMENT PERMIT

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: CAS Rodgers

PROPERTY LOCATION: 3330 McCaskey Road
Williamston, NC 27892

ADDRESS: P.O. Box 2952
Virginia Beach, VA 23450

New ☒ Repair _____ Expansion _____

Site Improvements required prior to Construction Authorization Issuance:

- The Initial Septic Area as outlined in the site sketch needs to be cleared of trees, tree stumps and other obstructions while preserving as much of the natural soil as possible.
- The permit holder is required to contact the Health Department after clearing the septic area to conduct an evaluation of the cleared Initial Septic System area. Improper land clearing activities may result in a denial of the lot.
- A follow-up visit is required before the Construction Authorization can be issued. A Construction Authorization is required before a Building Permit can be issued.

Type of Structure: 3 Bedroom Residence

Proposed Wastewater System Type: Accepted

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Maximum Number of Occupants: 6

Basement: _____ Yes ☒ No

Pump Required: _____ Yes _____ No ☒ May be required based upon final location and elevations of facilities.

Type of Water Supply: Public Water

Permit valid for: ☒ Five years
_____ No expiration

Permit conditions: _____

Authorized State Agent: Andrew Parker REHS Date: 10/13/20

See Attached Site Sketch

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit

Martin County
210 W. Liberty St.
Williamston, NC 27892
252.793.1819

Tyrrell County
408 Bridge St.
Columbia, NC 27925
252.793.1750

Washington County
198 Hwy. 45 North
Plymouth, NC 27962
252.793.3023

Site Sketch

Permit Number:

☒ Improvement Permit

☐ Construction Authorization

AS Rodgers

Applicant's Name

Andrew Parke REHS

Authorized State Agent

3330 McCaskey Road Williamston, NC 27892

Subdivision/Section/Lot Number

10/13/20

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = Not to Scale

Conditions:

Clear the Initial Septic Area as show of trees, tree stumps, and other obstructions while disturbing as little of the natural soil as possible. Contact the Health Department for a follow-up consultation.
Initial Septic Area approximately 80 feet by 21 feet with a trench depth of 12 inches in the designated area below. Must bring in additional soil to meet required 6-inches of soil cover over drain field.
Repair Septic Area approximately 80 feet by 21 feet with a trench depth of 12 inches in the designated area below. Must bring in additional soil to meet required 6-inches of soil cover over drain field.

