

**SURRY COUNTY HEALTH DEPARTMENT
IMPROVEMENTS PERMIT**

Owner Mark Watts Permit No. MJH112001-02
 Location Silviam Rd. to Ararat Rd. T/L Little Wtn. Ch. Rd.
T/L private drive just past Bull Run Ln. stay right to site on left.
 Parcel ID # 5936-0-46-1470 Lot Size 12± AC.

Note: This permit DOES NOT authorize the construction or installation of a septic tank system or any wastewater system. An **Authorization for Wastewater System Construction** must be obtained from the Health Department prior to the construction/installation of a system or the issuance of a building permit.

Use of Structure House
 No. of Bedrooms: 3
 Water Supply: Private System Public System _____
 No. of Employees _____ No. of Seats _____
 Basement: yes no
 Basement plumbing: yes no
 Improvements Permit: Expires in 5 Yrs. Does Not Expire _____

SEPTIC TANK SYSTEM DESIGN

Size of Tank 1000
 Size of Pump Tank N/A
 LTAR 0.43/721d
 Design Wastewater Flow 360 gpd
 Nitrification Field 900 Sq. Ft.
 No. of Lines 3
 Width of Lines 3'
 Length of Lines 100'
 Depth of Stone 12"

PERMIT SPECIFICATIONS: Follow contour of land, Honor all setbacks, Stay out of hollow!

- An Improvements Permit shall not be affected by changes in ownership. **THIS PERMIT IS SUBJECT TO REVOCATION IF SITE PLANS OR INTENDED USE CHANGE. ALTERATION OF THE SITE OR SOIL CONDITIONS MAY REQUIRE THE REVOCATION OF THIS PERMIT.**

Mark Watts
 Owner/Date

Joe Holder R.S.
 Env. Health Specialist

OPERATIONS PERMIT AND FINAL SEPTIC TANK SYSTEM DESIGN	
Size of Tank	<u>1000</u>
Dist. to prop. line	<u>10'</u>
Dist. to well	<u>N/A</u>
Dist. to foundation	<u>12'</u>
Nitrification Field	<u>900</u> Sq. Ft.
No. of Lines	<u>3</u>
Width of Lines	<u>3'</u>
Length of Lines	<u>100'</u>
Depth of Stone	<u>12"</u>
Contractor	<u>Chad Wolfe</u>
Completion Date	<u>7-9-02</u>
Env. Health Specialist	<u>Joe Holder R.S.</u>

