



Rockingham County Department of Health and Human Services

CERTIFICATE OF COMPLETION

Private Drinking Water Well

Applicant/Owner Name: TAMIE BERRY **Location:** 219 CART DR **Well Permit Number:** EHWP2204-015

Intended Use: Residential

Grout Inspection

Grout Depth: 20' (ft)

Grout Method: Hydrate in place

Grout Type: Bentonite Chips

Inspected by: Justin Swain

Date: 9/16/2022

Well Information

Casing Type: PVC

Casing Depth: 54 (ft)

Casing Diameter: 6 (in)

Well Depth: 405 (ft)

Yield: 2 (gpm)

Static Water Level: 80 (ft)

Wellhead Inspection

Casing Height: 12 (in)

Port/Vent: Yes

Seal: Yes

Hose Bibb: Yes

Threadless Tap: Yes

Well Tag Present: Yes

Date Drilled: 9/16/22

Pump Depth: 375

Pump Rating: 5 GPM

Pump Tag Present: Yes

Contractor Information

Well Contractor: Raymond Brown

Certification #: 2313

Pump Installer: Hall Well and Plumbing

Certification #: 3888-C

Notes: _____

Authorized Agent: _____

Angela Wyatt, REHS

REHS#: 1744

Date: 9/27/22

The well owner shall not place potential sources of groundwater contamination closer to the well than the separation distances specified in 15A NCAC 02C. This well was constructed in the designated area and according to the well construction permit and the Private Drinking Water Well Rules. Questions? (336) 342-8180