

Williamson County, Tennessee Sewage Disposal Management Department	<b>PERMIT FOR CONSTRUCTION OF SUBSURFACE SEWAGE DISPOSAL SYSTEM</b>	1320 West Main St, Ste 411 Franklin, Tennessee 37064 615-790-5751
<b>-- PERMIT VOID 3 YEARS AFTER ISSUE DATE --</b>		
PERMIT NO: SDM-CS-CON-2020-00050	GIS NO:	
PERMIT DATE: 12/03/2020	PROJECT ID: 450285	

NAME: Michael Delaney  
ADDRESS: 7638 YOUNGER CREEK ROAD, PRIMM SPRINGS, TN 38476 (Unverified)  
EMAIL: DHBuilders@aol.com  
PHONE: 954-214-2917

INSTALLATION:	New	TYPE OF SYSTEM:	CONVENTIONAL
PUMP TANK CAPACITY:		ESTABLISHMENT:	Residential
SEPTIC TANK CAPACITY:	1000	BEDROOMS:	4
SOIL EVAL. BASIS:	Soils typing by Soils Scientist - Extra High Intensity	OVERSIZED TUBS:	0
EST. ABSORPTION RATE:	45 MPI	TUB CAPACITY:	
GPD:	600	PERMIT ISSUED BY:	Elliott Eley
OTHER:			

- FIELD LINES TO BE LOCATED IN AREA "A" AS SHOWN ON THE PLAT.
- 420 LINEAR FEET OF FIELD LINES REQUIRED.
- NO PART OF THE FLAGGED SUBSURFACE SEWAGE DISPOSAL SYSTEM AREAS IS TO BE DISTURBED BY COMPACTION, CUTTING, OR FILLING. NOR IS ANY PART OF THE AREAS TO BE ENCROACHED UPON BY ANY PART OF THE HOUSE, DRIVEWAYS, OR ANY UNDERGROUND OR OVERHEAD UTILITIES (GAS, WATER, ELECTRIC, ETC.)
- ANY WELL, SPRING, OR CISTERN MUST MAINTAIN A MINIMUM OF 50 FEET FROM ANY PART OF THE FLAGGED SUBSURFACE SEWAGE DISPOSAL AREAS AND SEPTIC/PUMP TANK(S).
- WATER, GAS OR UNDERGROUND ELECTRIC LINES MUST MAINTAIN A MINIMUM OF 10 FEET AWAY FROM ANY PART OF THE FLAGGED SUBSURFACE SEWAGE DISPOSAL SYSTEM AREAS AND SEPTIC TANK.
- OVERHEAD UTILITIES MUST BE A MINIMUM OF 25 FEET FROM ANY PART OF THE FLAGGED SUBSURFACE SEWAGE DISPOSAL SYSTEM AREAS.
- FIELD LINES AND SEPTIC PUMP TANKS MUST BE A MINIMUM OF 20 FEET FROM ANY PROPERTY LINE.
- ANY CUTTING FOR THE PURPOSE OF HOUSE CONSTRUCTION, GREATER THAN 18 INCHES, MUST BE A MINIMUM OF 25 FEET AWAY FROM ANY PART OF THE FLAGGED SUBSURFACE SEWAGE DISPOSAL SYSTEM AREAS.
- A PUMP AND PUMP TANK (1200 GALLONS) MAY BE REQUIRED IF GRAVITY FLOW CANNOT BE OBTAINED.
- THIS APPROVAL IS LIMITED TO ONE- 4 BEDROOM SINGLE-FAMILY DWELLING.
- THE STUMP HOLES ARE TO BE ROLLED IN AND SMOOTHED PRIOR TO INSTALLATION AS SHOWN ON THE RECORDED PLAT.
- OVERSIZED BATHING FIXTURES (ANY TUBS EXCEEDING 30 GALLONS TO THE OVERFLOW) ARE NOT APPROVED FOR THIS LOT.
- THE INSTALLER MUST CONTACT WCDSDM PRIOR TO SYSTEM INSTALLATION TO INITIATE THE **PERMIT TO INSTALL** PROCESS.

*The recipient of this permit agrees to construct or have constructed the system described above in accordance with the Regulations to Govern On-Site Sewage Disposal Systems of the Williamson County Department of Sewage Disposal Management, as operated under the auspices of the Williamson County Board of Health, and T.C.A. 68-221-401 et. seq. All installers of subsurface sewage disposal systems must hold a valid annual license from the Williamson County Department of Sewage Disposal*

*Management.*