



**TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER RESOURCES
CERTIFICATE OF COMPLETION OF A SUBSURFACE SEWAGE DISPOSAL SYSTEM**

Issued to: Alan Boeckner
Location:
 County: Perry
 Address: 2234 Hwy 412 West
 City: Linden
 Subdivision: Tower Estates
 Lot #: 112
 Map: 075 Group: _____ Parcel: 012.00
 Installed by: Swarey
 Installer email: _____
 Number of Bedrooms: 3
 Gallons per Day: _____
 Estimated Soil Absorption Rate: 30 MPI

Type of System:
 Conventional
 Modified Conventional
 Conventional System Substitute
 Chamber
 Poly Expanded Styrene
 Large Diameter Gravelless Pipe
 _____ Gravel backfill in a 24 in. trench required?
 Low Pressure Pipe
 Mound
 Lagoon
 Subsurface Drip Disposal
 Other _____

Product: Infiltrator - Quick4 Plus Standard: 34" W x 12" H x 53" L

Septic Tank Manufacture: TCC
 Volume (gal): 1,000

Effluent Pump? No
 Effluent Pump Manufacture: _____
 Effluent Pump Tank Volume: _____ gallons

Was the electric inspected? _____
 Electric Inspection Ticket #: _____
 Electric Inspection Date: _____

- New Installation
- Repair Existing System
- System Modification
- Large System

Comments:

This system is approved using a 30% reduction in field line as per regulation.

Please see attached site drawing and any other supporting documentation.

Inspected by: Jacob Davis
 DWR Staff

01/07/2025
 Date

Tennessee Department of Environment and Conservation - Division of Water Resources Certificate of Completion of a Subsurface Sewage Disposal System



Issued To: Alan Boeckner
Location: 2234 Hwy 412W
Linden, Tn 37096
Tower Estates Lot 112

Inspector: Jacob Davis *Jacob Davis* ES2
Date: 1/7/25

General Notes:

- Please refer to the subsurface sewage disposal system details on the first page of the Certificate of Completion.
- Questions regarding the Certificate of Completion should be directed to the local Division of Water Resources representative.

The Subsurface Sewage Disposal System is Approved For:

- Residential: # of Bedrooms: 3
- Other: _____
- Gals/Day: _____ Public Water











