PERMIT FOR CONSTRUCTION OF SUBSURFACE SEWAGE DISPOSAL SYSTEM

REGION	COUNTY	ID-NUMBER	DATE
2	32	59-0006	01-28-82

STAFF	INSTALLATION:
123	(X) 1. New Installation ( ) 2. Repair to Existing System

MOORE, DONALD
Owner, Developer, Contractor, Installer, Etc.

To be constructed by HANKY SHEPARD
(Installer)

Construction of a subsurface sewage disposal system is hereby authorized at:

CHERRYBROOK S.D. LOT #6
(No. and street; Subdivision name and lot no.)

Such a system shall consist of a septic tank of 900 gals,
with 123 linear feet in 2 trenches,
96 inches wide, and 24-48 deep
or _____ .

Type of System: (X) 1. Standard ( ) 2. Alternating ( ) 3. Chapter 301 ( ) 4. Chapter 212 ( ) 5. Other

For: (X) 1. Residential: No. B/R 3
( ) 2. Commercial/Industrial; Gal/Day _____

Evaluation based Upon: ( ) 1. Soil Typing by Soil Scientist
(X) 2. Soil Percolation Tests
( ) 3. Other

Permeability Rate 17 min/in

The recipient of this permit agrees to construct or have constructed the system in accordance with the rules and regulations under the authority of TCA 53-2054. The recipient must notify the local health authority when the system is ready for inspection. If any part of system is covered before being inspected and approved, it shall be uncovered by the recipient of the permit at the direction of the local health authority.

_____ Date _____
(Signature of Recipient-Owner, Developer, Contractor, Etc.)

Issued at MORRISTOWN, Tennessee in the County of HAMBLEN

By _____ Date _____
(Local Health Authority)



65
52
6
123' OF FIELD LINE INSTALLED

Field Line
Solid Line
0 Depth in in.

Inspected By Linda Riddle
Local Health Authority

Date 01-28-82

Construction Approval: (X) 1. Yes ( ) 2. No

No. of Visits: 2

Time: 0 2 5

PH-1488
ES 8/79