

**MINNESOTA DEPARTMENT OF HEALTH  
WELL AND BORING RECORD  
Minnesota Statutes, Chapter 103I**

MINNESOTA UNIQUE WELL NO.

**717057**

WELL LOCATION  
County Name  
**Steele**

Township Name **Deerfield** Township No. **108N** Range No. **21W** Section No. **29** Fraction **SE SE SW**

WELL DEPTH (completed) **274** ft. Date Work Completed **2-25-05**

GPS LOCATION: Latitude \_\_\_\_\_ degrees \_\_\_\_\_ minutes \_\_\_\_\_ seconds \_\_\_\_\_  
Longitude \_\_\_\_\_ degrees \_\_\_\_\_ minutes \_\_\_\_\_ seconds \_\_\_\_\_



DRILLING METHOD  
 Cable Tool  Driven  Dug  
 Auger  Rotary  Jetted

House Number, Street Name, City, and Zip Code of Well Location  
**3738 NW 85th Ave., Owatonna**

DRILLING FLUID **Bentonite & Water** WELL HYDROFRACTURED?  Yes  No

Show exact location of well in section grid with "X". Sketch map of well location. Showing property lines, roads and buildings

FROM \_\_\_\_\_ ft. TO \_\_\_\_\_ ft.



USE  
 Domestic  Monitoring  Heating/Cooling  
 Noncommunity PWS  Environ. Bore Hole  Industry/Commercial  
 Community PWS  Irrigation  Remedial  
 Dewatering

CASING Drive Shoe?  Yes  No  
 Steel  Plastic  Threaded  Welded

CASING DIAMETER WEIGHT HOLE DIAM.  
**5** in. to **175** ft. **15** lbs./ft. **10** in. to **175** ft.  
**5** in. to **274** ft.

PROPERTY OWNER'S NAME/COMPANY NAME  
**Dave Schlobohm**

SCREEN OPEN HOLE  
Make \_\_\_\_\_ FROM **175** ft. TO **274** ft.

Property owner's mailing address if different than well location address indicated above.  
**505 No. Cedar  
Owatonna, MN 55060**

Type \_\_\_\_\_ Diam. \_\_\_\_\_  
Slot/Gauze \_\_\_\_\_ Length \_\_\_\_\_  
Set between \_\_\_\_\_ ft. and \_\_\_\_\_ ft. FITTINGS \_\_\_\_\_

STATIC WATER LEVEL  
**115** ft.  below  above land surface Date measured **12-20-04**

WELL OWNER'S NAME/COMPANY NAME  
**Dave Schlobohm**

PUMPING LEVEL (below land surface)  
**117** ft. after **2** hrs. pumping **15** g.p.m.

Well owner's mailing address if different than property owners address indicated above.  
**RECEIVED  
MAY 2005  
WELL MGT.**

WELL HEAD COMPLETION  
 Wellless adapter manufacturer **Baker** Model **6PS56BS4C0**  
 Casing Protection  12 in. above grade  
 At-grade (Environmental Wells and Boring ONLY)

GROUTING INFORMATION  
Well grouted  Yes  No  
Grout material  Neat cement  Bentonite  Concrete  High Solids Bentonite  
from **0** to **175** ft. **2 1/2** yds.  bags

GEOLOGICAL MATERIALS	COLOR	HARDNESS OF MATERIAL	FROM	TO
Clay	Blue	Med	0	55
Sand	Gray Tan	Soft	55	100
Clay	Blue	Med	100	110
Shale	Gray	Med	110	136
Platteville Lime	Brwn	Hard	136	149
Shale	Gray	M Hard	149	157
St. Peter Sandstone	White	Med	157	273
Shakopee Dolomite	Brown	Hard	273	274

NEAREST KNOWN SOURCE OF CONTAMINATION  
**85** feet **West** direction **Drain** type  
Well disinfected upon completion  Yes  No

PUMP  
 Not installed Date installed **12-20-04**  
Manufacturer's name **Aermotor**  
Model number **S12-75** HP **3/4** Volts **230**  
Length of drop pipe **130** ft. Capacity **12** g.p.m.  
Type  Submersible  L.S. Turbine  Reciprocating  Jet

ABANDONED WELLS  
Does property have any not in use and not sealed well(s)  Yes  No

VARIANCE  
Was a variance granted from the MDH for this well?  Yes  No TN#

WELL CONTRACTOR CERTIFICATION  
This well was drilled under my supervision and in accordance with Minnesota Rules, Chapter 4725. The information contained in this report is true to the best of my knowledge.

REMARKS, ELEVATION, SOURCE OF DATA, etc.

**Born Well Drilling** **81744**  
Licensee Business Name Lic. or Reg. No.  
**Dennis Born** **3-1-05**  
Authorized Representative Signature Date  
**Dennis Born**  
Name of Driller

MINN. DEPT OF HEALTH COPY **717057**

3-7-05 B