

**DODGE COUNTY SEPTIC SYSTEM DIVISION
 INSPECTION FORM FOR ON-SITE SEPTIC SYSTEM**

Date of Inspection: 10/20/22 & 11/2/2022 Time: _____ Weather Conditions: _____

LOCATION/SETBACKS:

Buildings to Tank(s) _____
 Tank to Drainfield (First drop box) _____
 Soil Verification Located in Drainfield/Mound _____
 Well to Tank _____
 Well to Drainfield _____

_____ 60'
 _____ 160'
 _____ Yes
 _____ 59'
 _____ 100'

MOUND/AT-GRADE:

Percent slope _____ 2%
 Media _____ LP Chambers
 Product Manufacturer/Type _____ Infiltrator
 Sand Distributor Information _____ Farmers Topsoil
 Upslope Dike Width _____
 Downslope Dike Width _____
 Sand Depth Below Media _____ 20"
 Perforation Size, Spacing, Pipe Diameter _____ 1/4" 3", 2" lats
 Dimensions of Bed _____ 9' X 44'
 Dimensions of Sand Base _____ All of absorption
 Final Cover _____ Observed

TANK(S):

of Tanks _____
 Manufacturer _____
 Septic Capacity _____
 Pump Capacity _____
 Inspection Pipes / Maintenance Hole Access _____

_____ 1-1600 combo
 _____ Wieser
 _____ 1000g
 _____ 600g
 _____ 3 to surface, 2' risers

PUMP:

Pump Manufacturer _____ Goulds
 Pump Model _____ EPO511
 Pump Size _____ 1/2hp
 Size of Discharge Line _____ 2"
 Drain Back to Tank _____ Yes
 Electrical Installed _____ Not at inspection

TRENCH/PRESSURE BED:

Media _____ NA
 Product Manufacturer/Material Distributor Information _____
 Type of Distribution _____
 Trench Depth _____
 Trench Length _____
 Bed Dimensions _____
 Trench Level _____
 Drop Box Material/Manufacturer _____

_____ NA

OTHER:

Filter- Make/Model _____ PL-525
 Event Counter _____

ATTACH DRAWING OF SYSTEM

10/20/2022: Laterals and chambers on at inspection, 20" measured sand lift on North & South end.
 11/02/2022: 1600g combo tank installed, 59' measured to well, straw and seed on mound at inspection. Installer tied on to existing building sewer at 50' from well.

STATUS OF SYSTEM:

Based on the inspection conducted above and information provided with the permit application the system status is
 In Compliance, therefore, this document is a Certificate of Compliance.
 (Choose: In Compliance OR Failing) (Choose: Certificate of Compliance OR Notice of Noncompliance).

I hereby certify with my signature as a qualified employee that based on the certifications of the site evaluator, designer, and installer that my observations recorded on this form are accurate as of the date at the top of this form for the site stated above. No determination or guarantee of future hydraulic performance is or can be made due to unknown conditions during system construction, future water usage over the life of the system, abuse of the system, and/or inadequate maintenance all of which will adversely affect the life of the system.

Elizabeth Harbaugh

Digitally signed by Elizabeth Harbaugh
 DN: cn=Elizabeth Harbaugh, o=Dodge County, MN,
 ou=Dodge County, email=elizabeth.harbaugh@dodgecountymn.us, c=US
 Reason: I am approving this document.
 Location: your signing location here
 Date: 2022.11.16 11:53:31
 File: PlantonPDF Version: 9.7.5

11/16/2022

C484

Inspector's Signature

Date

License Number

Owner given system information Yes ___ No ___

*The sewer line from the building to the tank is solely mapped for future site development purpose(s). The installer is responsible to meet Minnesota Plumbing Code requirements for connecting the sewer line from the building to the septic tank. A new septic system compliance inspection determines that Minnesota Rules 7080-7083 have been met during system installation (tank to drain field).

*A Certificate of Compliance is valid for 3 years on existing septic systems and 5 years on new septic systems per state regulation. Dodge County Ordinance does not require a septic inspection during a property transfers if a Certificate of Compliance has been issued for the system within 10 years of the property transfer. This is no way infers that a Certificate of Compliance is valid for 10 years. The seller/buyer, authorized representative(s) and/or financial institution must determine if a compliance inspection shall be completed during a property transfer after a valid compliance inspection has expired.