



**TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER RESOURCES
CERTIFICATE OF COMPLETION OF A SUBSURFACE SEWAGE DISPOSAL SYSTEM**

Issued to: Nick Holman

Location:

County: Jackson

Address: 234 Bob Johnson Ln

City: Cookeville

Subdivision: Hawkins Property

Lot #: 1

Map: 093 Group: _____ Parcel: 088.03

Installed by: Josh Morris

Installer email: _____

Number of Bedrooms: 3

Gallons per Day: 0

Estimated Soil Absorption Rate: 60 MPI

- ☒ New Installation
☐ Repair Existing System
☐ System Modification
☐ Large System

Type of System:

☐ Conventional

☐ Modified Conventional

☒ Conventional System Substitute

☒ Chamber

☐ Poly Expanded Styrene

☐ Large Diameter Gravelless Pipe

Gravel backfill in a 24 in. trench required?

☐ Low Pressure Pipe

☐ Mound

☐ Lagoon

☐ Subsurface Drip Disposal

☐ Other _____

Product: Infiltrator - Arc 36: 34.5" wide x 13" high

Septic Tank Manufacture: FSTC

Volume (gal): 1,000

Effluent Pump? No

Effluent Pump Manufacture: _____

Effluent Pump Tank Volume: _____ gallons

Was the electric inspected? _____

Electric Inspection Ticket #: _____

Electric Inspection Date: _____

Comments:

Please see attached site drawing and any other supporting documentation.

Inspected by: Braxton Patton
DWR Staff

04/20/2026
Date

Tennessee Department of Environment and Conservation - Division of Water Resources
Certificate of Completion of a Subsurface Sewage Disposal System



Issued To: Nick Holman
Location: 234 Bob Johnson Lane
Cookeville, TN 38501
Parcel ID: 093 088.03
Hawkins Property, Lot 1
Inspector: Braxton Patton *Braxton Patton ES*
Date: 20 Apr 2026

General Notes:

- Please refer to the subsurface sewage disposal system details on the first page of the Certificate of Completion.
- Questions regarding the Certificate of Completion should be directed to the local Division of Water Resources representative.

The Subsurface Sewage Disposal System is Approved For:

(X) Residential: # of Bedrooms: 3

() Other: _____

Gals/Day: _____

Septic Tank: FSTC 1000
Product: Arc 36

L1: 35'
L2: 125'
L3: 75'
235 total footage

30% reduction taken

All field line within
2" tolerance according
to regulations

Tank coord
36.23948
-85.61164









