

ALEXANDER COUNTY HEALTH DEPARTMENT

Call 704-632-9704 between 8:00 - 9:00 AM, Mon-Fri

322 1st Avenue SW, Taylorsville, NC 28681

Improvement Permit and Operation Permit

(Ground Absorption Sewage Disposal System-Article 11 of Chapter 130A 15A NCAC 18A. 1900)

Owner Gordy Dart Date 7-18-00

Site 51 Fred Jolly Ln

Location Hwy 165, @ Fred Jolly Ln., keep left, thru gate, to home

Subdivision _____ Lot No. _____ Lot Size 10.03 Acres

Basement Yes ☐ No ☒ Basement Plumbing Yes ☐ No ☒

HOUSE	MOBILE HOME	BUSINESS	SITE EVALUATION
Living Units <u>1</u>	No. Bedrooms <u>4</u>	No. Baths <u>2</u>	
Garb. Disp. Unit	yes ☐ no ☒		
SEPTIC TANKS SYSTEM			
Size of Tank <u>1500</u>	Stb No. <u>268</u>	<u>AD</u>	
Installed by <u>Scott Greene</u>			
Nitrification Field <u>1800</u>	Sq. Ft.		
Number of Lines <u>5</u>			
Length & Width of Lines: <u>3 x 120'</u>			
A. Trench System ☒ Bed System ☐			
Conditions <u>96 tons #5 stone</u>			
<u>12" stone</u>			
<u>12"-24" natural cover</u>			
<u>5 boxes</u>			
Water Supply: Spring ☐ Well ☒ Other ☐			

* Note: GS 130A-336(b) GS 130A-335(f) The following shall apply to the application and the improvement permit/ authorization for waste water construction if one is issued. The improvement permit/authorization for waste water construction shall become invalid immediately if any changes are made on the site. For example: 1) Increasing the size of the home or number of bedrooms. 2) Relocation of house site or altering size or location of the lot. 3) Grading, cutting or filling the area designed for the sewage system and the 100% repair area or the location of a driveway, utilities, mulch beds, gardens, low areas, gutter lines, etc. on these areas. After the septic tank system has been installed, landscaping should be done in such a way as to direct the movement of water, surface and/or internal water, away from the septic tank system and designated repair area. 4) The placement of or discovery of an existing well which is too close to the sewage system and 100% repair area, as required by state law. 5) Anything else which occurs that would cause the permit to become void as stated in Article 11 Chapter 130A of the General Statutes of North Carolina. The authorization for waste water construction is also subject to the above conditions and shall otherwise be valid for sixty (60) months from date of issue. Note: The lot size dimensions were provided by the owner and/or applicant. Also, there is no guarantee that this system or any other will function satisfactorily for any given period of time.

I have read and fully understand the above.

SIGN Nancy Dart DATE 7-19-00
(Owner or Authorized Agent)

- ☒ Improvement Permit
- ☐ Repair Permit
- ☐ Authorization of Existing System
- ☒ Authorization for Waste Water System Construction

Owner Gordy Dart 3772
IMPROVEMENT PERMIT By Bert Hiler
Date 7-18-00

AUTHORIZATION FOR WASTE WATER SYSTEM CONSTRUCTION

By Bert Hiler
DATE 7-18-00

The issuance of this permit does not preclude the Permittee from complying with any and all statutes, rules, regulations, or ordinances which may be imposed by other government agencies (local, state, and federal) which have jurisdiction.

See attached diagrams for installation specifications.

Septic tank contractor shall call prior to installation of septic system Monday through Friday 8-9 am.

The applicant, owner, builder shall be responsible for plumbing the home to ensure that a gravity septic system can be installed. The septic tank shall not be installed deeper than 6" below the surface of the natural ground level.

Surface diversions and/or interceptor drains may be required in the future.

Note: Minimum distances from wells to area designated for sewage systems can vary from 50' to 100' depending on applicable factors which may apply as required in Article 11 of Chapter 130 of the General Statutes of North Carolina. Well shall be located a minimum of 100' from any designated septic area in accordance with Rules .1950 & .1956(b) Nitrification fields and repair areas shall not be located under paved areas or areas subject to vehicular traffic.

OPERATION PERMIT
BY Bert Hiler DATE 9-14-00
Authorization of Existing System
BY _____ DATE _____

ALEXANDER COUNTY ENVIRONMENTAL HEALTH

Phone: (828)632-9704 Fax: (828)632-9008
IMPROVEMENT PERMIT DIAGRAM

Issued Permit # 3772

Date: 7/18/00
Owner: Gordy Part
EHS: Bert Gilk

Operation Permit Completed on: 8-8-00
EHS: Bert Gilk

