

**OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES**

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

1318

WELL PERMIT NUMBER 251501 - -
DIV. 1 WD 23 DES. BASIN MD

APPLICANT

Lot: 105 Block: Filing: 16 Subdiv: INDIAN CREEK

MARION & SHIRLEY FRANCE
64 COLUMBIA LANE
FLORISSANT, CO 80816-

(719) 748-3236

APPROVED WELL LOCATION

TELLER COUNTY
SE 1/4 SW 1/4 Section 29
Township 12 S Range 70 W Sixth P.M.

DISTANCES FROM SECTION LINES

450 Ft. from South Section Line
1430 Ft. from West Section Line

UTM COORDINATES

Northing: Easting:

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a residential site of 4.06 acre(s) described as lot 105, filing 16, Indian Creek Subdivision, Teller County.
- 4) The use of ground water from this well is limited to ordinary household purposes inside one single family dwelling. The ground water shall not be used for irrigation or other purposes.
- 5) The maximum pumping rate of this well shall not exceed 15 GPM.
- 6) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 7) This well shall be constructed not more than 200 feet from the location specified on this permit.

NOTE: Expired permit no. 142850, was previously issued for this lot. *DB 6/30/03*

APPROVED
SKB

State Engineer

DATE ISSUED 06-30-2003

By

EXPIRATION DATE 06-30-2005

Receipt No. 0512075