

Other Options

[Return to menu](#)
[Plot this site in State Library Digital Atlas](#)
[Plot this site in Google Maps](#)
[View scanned well log_\(11/21/2006 1:27:54 PM\)](#)

Section 7: Well Test Data

Total Depth: 180
Static Water Level: 90
Water Temperature:

Air Test *

20 gpm with drill stem set at 178 feet for 1 hours.
Time of recovery 1 hours.
Recovery water level 90 feet.
Pumping water level 176 feet.

** During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.*

Section 8: Remarks

Section 9: Well Log

Geologic Source

Unassigned

[illegible]

Casing

Completion (Perf/Screen)

Annular Space (Seal/Grout/Packer)

Driller Certification

Name:
Company: LINDSAY DRILLING CO INC
License No: WWC-253
Date Completed: 7/9/1998