

Ranchers Well Service
P.O. Box 232
Sonoita AZ 85637
520-860-0030
ROC K53 287355
June 3, 2016

Angela Styczykowski

RE: Well Inspection at 4165 E Hwy 82.

Static Water Level 360 feet.

Casing 6" steel at surface. Pump in well produces + or - 15 GPM stabilized at 361 feet. Pumped for 60 minutes. 2HP Pump in well, we used the existing pump for this test. Well pumps into storage tank.


All equipment is working properly at this time and the system is capable of providing water for residential needs.

Thanks,

Denny Hubbell

Ranchers Well Service
2609 Hwy 82
P.O. Box 232
Sonoita AZ 85637
Phone: 5208600030

INVOICE



Ranchers Well Service

Angela Styczkowski
Angela Styczkowski
4165 East Hwy 82
Sonoita AZ 85637

Invoice #:	1757
Date:	June 3, 2016
Balance Due (USD):	\$350.00

Task	Time Entry Notes	Rate (\$)	Hours	Line Total (\$)
Well Inspection	Inspect well.	350.00	1	350.00
NOTES: Thanks for your business!				
Subtotal:				350.00
Total:				350.00
Amount Paid:				0.00
Balance Due (USD):				\$350.00
Due upon receipt of invoice. All materials remain property of Ranchers Well Service and its suppliers until invoice is paid in full. We reserve the right to remove materials in the event of non-payment of any portion of invoiced amount. Unpaid balances carry a 1.5% per month service charge.				

on line
6/13/16 (date delivered)